

## OPERATIONS MANAGER - STATUS REPORT

October 12, 2023

### Treatment Plants

The treatment plants continue to meet constituent discharge requirements on a routine basis. There have been no discharge violations due to Equipment Failure.

### Collection System

Crews are continuing with regular operations, daily inspections of District lift stations, issuance of correction notices for repairs on private laterals, and inspections on all repairs. Throughout the month, collection staff inspected waterways and the district effluent outfall line after all rain events.

For September the district hydraulically cleaned 8'439 feet of line and raised 12 manholes in assessment districts 11,12.

Regulatory Compliance: District is maintaining a >90% compliance currently through the 2023 calendar year...i.e., < 2 SSO's, RWQCB Plant Discharge Requirements.

### Facilities & Infrastructure PowerPoint presentation

There have been no discharge violations due to Equipment Failure.

### Talking Points (this is for anything you want to discuss about the plants or crews)

- Construction continues on the plant upgrade as scheduled the protective coating has been applied to the sweep arm, skimmer arm, and bridge of the Primary Clarifier. The old damaged asphalt has been removed and the ground is being prepped for the new asphalt to be installed in the coming week.
- Concrete Bollards have been installed to protect electrical panels and the new generator at H.C. Our Maintenance crew made a critical repair last week on the erosion of the driveway near the trailer at H.C. making it possible for the asphalt crew to continue their contracted work unimpeded.
- The new screw presses have been mounted on their concrete pedestals in the new Press building. The conveyor system and pumps are in the finishing stages assembly and are being mounted this week, the piping for the pumps is partially assembled and should be completed soon as well.